



October 15, 2009

Mr. Richard Conforti, P.E.
Environmental Engineer
Waste and Hazardous Materials Division
Department of Environmental Quality
PO Box 30241
Lansing, MI 48909-7741

*Subject: Monthly Status Report – September 2009
Coldwater Road Landfill
1245 East Coldwater Road, Flint, MI
MID 005 356 860 / Consent Order No. 64-05-92*

Dear Mr. Conforti:

In accordance with requirements of the above referenced Consent Order, we are providing you with this Monthly Status Report for the month of September 2009.

1. Work Completed This Reporting Period

- Dewatering of the leak detection vaults occurred on September 16, 2009.
- Due to exceedances of amenable cyanide and cooper, the accumulated liquid in the accumulation tank was removed by Dynecol Inc. on September 4, 2009.
- Sediment from the accumulation tank was removed by Young's Environmental on September 4, 2009.
- Quarterly site inspection occurred on September 24, 2009.
- Landfill cap inspection occurred on September 2, 2009 and September 17, 2009.

2. Summaries of Findings

- During landfill cap inspections, approximately 89 trees and shrubs were removed and traps were set over active animal burrows.

3. Summaries of Changes

- None.

4. Summaries of all Contact with Local Community

- None.

5. Summaries of all Problems

- The flow totaling meter is not operating properly.

6. Actions Being Taken to Rectify Problems

- Repair/replacement of meter is being investigated.

7. Changes in Personnel

- None.


8. Projected Work

- Dewatering of the leak detection vaults is scheduled for October 14, 2009.
- Sampling and discharge of accumulated liquids will be conducted as needed.

9. Reports/Data

- Leak detection Vaults A, B, C, D, E and F were pumped on September 16, 2009. During September 2009, no water was removed from Vaults A, and D. However, 107 gallons were removed from Vault B, 36 gallons were removed from Vault C, 280 gallons were removed from Vault E, and 137 gallons were removed from Vault F. Total volume of water removed from the vaults during the month of September was 657 gallons (including rinse water). According to the master flow meter, a total of 494 gallons were discharged to the accumulation tank; therefore, -163 gallons were pumped from the sumps during the month of September 2009.

The following graph presents the vault dewatering data in graphical format for the past year:



Please call me at 248-477-5701 if you have any questions.

Very truly yours,

O'BRIEN & GERE ENGINEERS, INC.

Clifford Yantz
Technical Associate

cc: Mr. Ken Richards – Motors Liquidation Company
Ms. Marianne Secrest – O'Brien & Gere