

# General Discharge Permit

## Groundwater Remediation

City of Indianapolis – Department of Public Works

### Authorization to Discharge Wastewater to the Municipal Sewer System

In compliance with Section 671-41 of Chapter 671 of the Municipal Code of the City of Indianapolis and Marion County and in accordance with General Ordinance 77 – 1984, this facility is authorized to discharge wastewater to the Indianapolis municipal sewer system.

**Remediation and Liability Management Company, Inc.**  
**Closed Haz. Waste Surface Impoundment – Plant 5 – former Allison Gas Turbine Div.**  
**2701 West Raymond Street**  
**Indianapolis, IN 46203**

This permit shall become effective on October 1, 2008 and will expire on July 31, 2013. Discharge limits shall be monitored by the permittee as specified below:

<u>Effluent Characteristics</u>	<u>Daily Maximum (mg/l)</u>	<u>Monitoring Frequency</u>	<u>Sample Type</u>
Flow	N/A	Continuous	Metered
pH	5.0 – 12.0 S.U.	Monthly	Grab
Chlorinated Organic Compounds*	0.05	Monthly	Grab

\* The reported Chlorinated Organic Compounds value shall represent the sum of the analytical concentrations, greater than 0.005 mg/l, for 1,1-dichloroethane, cis-1,2-dichloroethane, tetrachloroethene, trichloroethane, 1,1,1-trichloroethane, and vinyl chloride.

## CONDITIONS

1. Samples and measurements taken shall be representative of the volume and nature of the monitored discharge.
2. The permittee shall submit the “Statement of Industrial Waste” form to Veolia/Indianapolis Water containing flow results obtained during the previous month. The form shall be submitted no later than the 25<sup>th</sup> day of the month following each completed monitoring period.
3. Reporting of monthly monitoring results is not required unless a violation occurs. Any non-compliance must be reported in accordance with Section 671-61. Reports shall be submitted to:  
City of Indianapolis – Belmont AWT  
2700 South Belmont Avenue  
Indianapolis, IN 46221  
Attn: Industrial Pretreatment Program (IPP)
4. Discharge of the extraction wells located within the slurry wall of the impoundment is prohibited during periods when combined sewer overflows (CSOs) are occurring in the Indianapolis sewer system. These overflows result from stormwater run-off or snowmelt. If the CSO discharge condition is unclear, the permittee shall obtain guidance from the Industrial Pretreatment Program by calling 317-639-7049.


5. The permitted wastewater shall be discharged at a rate not to exceed 200 gallons per minute.
6. Renewal authorization must be submitted no later than 60 days prior to the date of expiration.
7. All other terms and conditions found in Chapter 671 relative to sewer users are in effect. A copy of the municipal code can be accessed at: <http://www.indygov.org>

Signed this 20<sup>th</sup> day of August, 2008 by authority of the Director of the Department of Public Works, City of Indianapolis, Indiana.

*for Cheryl Carlson*  
\_\_\_\_\_  
Patrick Carroll  
Deputy Director, DPW

August 26, 2008

City of  
**Indianapolis**  
Gregory A. Ballard, Mayor



CERTIFIED MAIL # 7001 2510 0005 9219 6000

Mr. David Favero, Contract Project Manager  
Remediation and Liability Management Company, Inc.  
1210 South 5<sup>th</sup> Street  
Springfield, IL 62703

Re: Closed Hazardous Waste Surface Impoundment – Plant 5 – former Allison Gas Turbine Div.  
2701 West Raymond Street

Dear Mr. Favero:

Your application for an Industrial Discharge Permit has been processed in accordance with Chapter 671, Article III of the Municipal Code of Indianapolis and Marion County, Indiana. The enclosed **General Discharge Permit** regulates your facility that discharges into the Indianapolis sewer system. All discharges from this facility must be in full accordance with the terms and conditions of this permit and Chapter 671 of the Municipal Code of the City of Indianapolis and Marion County.

General discharge permits require monthly monitoring of specific effluent parameters. Monthly reporting of the monitoring results is not necessary unless a violation has been noted. Whenever a violation occurs, notification within **24 hours** of knowledge of the noncompliance must be given. A written explanation must also be submitted within five (5) working days to explain the nature of the violation and action taken to prevent a recurrence. Resampling must occur within thirty (30) days of the noncompliance. Section 671-61 of the Indianapolis Code provides further details.

In addition, results of monthly flow measurement must be reported to Veolia/Indianapolis Water on the "Statement of Industrial Waste" form. The completed form is due prior to the 25<sup>th</sup> of each month following the monitoring period.

If you have any questions, please contact Mr. Kim Cussen at (317) 639-7049.

Sincerely,

*for* Patrick Carroll  
Deputy Director, DPW

PC/kwc  
08kwc060

Enclosure

cc: Cheryl Carlson, Enforcement Manager, Office of Environmental Services  
Mr. Kim Cussen, IPP Specialist, United Water  
Kathy Hargraves, Revenue and Billing Manager, Dept. of Public Works

Department of Public Works  
Office of Environmental Services

Office of Environmental Services | (317) 327-2234  
2700 South Belmont Avenue | (fax) 327-2274  
Indianapolis, Indiana 46221 | www.indy.GOV

