



17303
\$L(S)

YPSILANTI COMMUNITY UTILITIES AUTHORITY

2777 STATE ROAD
YPSILANTI, MICHIGAN 48198-9112
TELEPHONE: (734) 484-4600
FAX: (734) 484-3369
WEBSITE: www.ycua.org

November 27, 2013

Ms. Beth Landale
Project Manager
Conestoga-Rovers & Associates
14496 Sheldon Road, Suite 200
Plymouth, MI 48170

RECEIVED

DEC - 3 2013

CRA-DETROIT

RE: Monitoring Event Analytical Results (I.U. Permit #RA 12-15)

Dear Ms. Landale:

Enclosed please find the results for the recent monitoring event of the industrial effluent at Outfall 001 located at 2901 Tyler Road in the Township of Ypsilanti. The monitoring event was conducted by the industrial surveillance staff of the Ypsilanti Community Utilities Authority. All analytical test results are within the parameters of the current Ypsilanti Township Sewer Use Ordinance and/or Industrial User Permit #RA 12-15.


Thank you for your continued dedication and support of the environment. Please contact me with any questions you may have regarding these results by phone at 734-484-4600 ext.123 or by email at lblackburn@ycua.org.

Sincerely,

Luther Blackburn
YCUA Compliance Supervisor

Enclosure: YCUA Laboratory Report

Cc: YCUA Compliance Department File



2777 State Road, Ypsilanti, MI 48198-9112
 Telephone: (734) 484-4600 Ext. 155
 Fax (734) 544-7149

LABORATORY REPORT

CLIENT/FACILITY NAME	R.A.C.E.R. Trust (Company Vehicle Operations Site) 2901 Tyler Road Ypsilanti, MI 48198
SAMPLE MATRIX:	Wastewater
REPORT DATE:	November 27, 2013
SAMPLING LOCATION(S):	Post treatment and prior to discharge into MH6, located 166 feet from south fence line and 71 feet from east fence line.
SAMPLE DATE(S):	Grab Samples: October 30, 2013; Composite Sample: October 30, 2013

PARAMETER	ANALYTICAL RESULTS	UNITS	MDL	DATE OF ANALYSIS	ANALYTICAL METHOD	ANALYST'S INITIALS
pH (Field Reading)	7.79	s.u.	N/A	October 30, 2013	SM 4500-H B	A.M.
Oil and Grease	ND	mg/l	5.0	November 15, 2013	EPA 1664A	K.L.
Biochemical Oxygen Demand	22.4	mg/l	2.0	November 5, 2013	SM 5210B	L.C. / K.L.
Chemical Oxygen Demand	73	mg/l	40	November 15, 2013	SM 5220D	K.L.
Ammonia Nitrogen	0.84	mg/l	0.05	October 31, 2013	SM 4500-NH3 D	L.C.
Total Phosphorus	0.03	mg/l	0.02	October 31, 2013	EPA 365.3	L.C. / K.L.
Total Suspended Solids	2.0	mg/l	1.0	October 31, 2013	SM 2540D	K.L.

APPROVED BY _____

Luther Blackburn, Compliance Supervisor

MDL = Method Detection Level
 ND = Not detectable at or above the MDL
 MPN = Most Probable Number
 N/A = Not Applicable



2777 State Road, Ypsilanti, MI 48198-9112

Telephone: (734) 484-4600 Ext. 155

Fax (734) 544-7149

LABORATORY REPORT

CLIENT/FACILITY NAME	R.A.C.E.R. Trust (Company Vehicle Operations Site) 2901 Tyler Road Ypsilanti, MI 48198
SAMPLE MATRIX:	Wastewater
REPORT DATE:	November 27, 2013
SAMPLING LOCATION(S):	Post treatment and prior to discharge into MH6, located 166 feet from south fence line and 71 feet from east fence line.
SAMPLE DATE(S):	Grab Samples: October 30, 2013; Composite Sample: October 30, 2013

PARAMETER	ANALYTICAL RESULTS	UNITS	MDL	DATE OF ANALYSIS	ANALYTICAL METHOD	ANALYST'S INITIALS
Phenol (4-AAP)	See Attached Report	µg/l			EPA 420.1	Brighton Analytical, L.L.C.
Volatile Analysis		µg/l			EPA 624	
Mercury Analysis		µg/l			EPA 245.2	
Semi-Volatile Analysis		µg/l			EPA 625	
PCB Analysis		µg/l			EPA 608	

APPROVED BY


 Luther Blackburn, Compliance Supervisor

MDL = Method Detection Level

ND = Not detectable at or above the MDL

MPN = Most Probable Number

N/A = Not Applicable



2105 Pless Drive • Brighton, Michigan 48114 • Phone (810) 229-7575 • Fax (810) 229-8650 • E-mail bai-brighton@sbcglobal.net

November 08, 2013

Ypsilanti Comm. Utilities Auth.
2777 State Rd.
Ypsilanti, MI 48198

Subject: Racer Trust CVO Site
CA#94

Dear Mr. Blackburn :

Thank you for making Brighton Analytical, L.L.C. your laboratory of choice. Enclosed are the results for the samples submitted on 11/01/2013 for the above mentioned project. NELAP/TNI Accredited Analysis and MDEQ Drinking Water Certified Analysis will be identified in their respective reporting formats. Duplicate copies can be supplied at your request for a fee of \$20.00 per copy.

The invoice for this project will be mailed with a copy of the report. If you have any questions concerning the data or invoice, please don't hesitate to contact our office. Please reference Brighton Analytical, L.L.C. Project ID 27057 when calling or emailing. We thank you for this opportunity to partner with you on this project and hope to work with you again in the future.

Sincerely,
Brighton Analytical, L.L.C.





Brighton Analytical, L.L.C.
2105 Pless Drive
Brighton, Michigan 48116
Phone: (810) 229-7575 FAX: (810) 229-8650
e-mail: bai-brighton@sbcglobal.net

Sample Date: 10/30/2013
Submit Date: 11/1/2013
Report Date: 11/6/2013

To: Ypsilanti Comm. Utilities Auth.
2777 State Rd.
Ypsilanti, MI 48198

BA Report Number: 27057
BA Sample ID: BZ02770

Project Name: **Racer Trust CVO Site**
Project Number: **CA#94**
Sample ID: **Racer CVO Effluent**

Parameters	Results	Units	DL	Method Reference	Analyst	Analysis Date
Organic Analysis						
Phenol (4-AAP)	30	ug/L	10	EPA 420.1	RM	11/6/2013

DL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

Released by:
Date:

[Signature]
11/8/13



Brighton Analytical, L.L.C.
2105 Pless Drive
Brighton, Michigan 48116
Phone: (810) 229-7575 FAX: (810) 229-8650
e-mail: bai-brighton@sbcglobal.net

Sample Date: 10/30/2013
Submit Date: 11/1/2013
Report Date: 11/8/2013

To: Ypsilanti Comm. Utilities Auth.
2777 State Rd.
Ypsilanti, MI 48198

BA Report Number: 27057
BA Sample ID: BZ02769

Project Name: **Racer Trust CVO Site**
Project Number: **CA#94**
Sample ID: **Racer CVO Effluent**

Parameters	Results	Units	DL	Method Reference	Analyst	Analysis Date
Total Metal Analysis						
Mercury	Not detected	ug/L	0.2	EPA 245.2	KW	11/6/2013
Mercury (digestion)	Digested			7470/7471	KW	11/6/2013

DL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

Released by:
Date:

[Signature]
11/8/13



Brighton Analytical, L.L.C.
2105 Pless Drive
Brighton, Michigan 48116
Phone: (810) 229-7575 FAX: (810) 229-8650
e-mail: bai-brighton@sbcglobal.net

To: Ypsilanti Comm. Utilities Auth.
2777 State Rd.
Ypsilanti, MI 48198

Sample Date: 10/30/2013
Submit Date: 11/1/2013
Report Date: 11/8/2013

BA Report Number: 27057
BA Sample ID: BZ02771

Project Name: Racer Trust CVO Site
Project Number: CA#94
Sample ID: Racer CVO Effluent

Parameters	Results	Units	DL	Method Reference	Analyst	Analysis Date
Volatile Analysis						
Benzene	Not detected	ug/L	1	EPA 624	CW	11/6/2013
Bromodichloromethane	Not detected	ug/L	1	EPA 624	CW	11/6/2013
Bromoform	Not detected	ug/L	1	EPA 624	CW	11/6/2013
Bromomethane(Methyl Bromide)	Not detected	ug/L	1	EPA 624	CW	11/6/2013
Carbon tetrachloride	Not detected	ug/L	1	EPA 624	CW	11/6/2013
Chlorobenzene	Not detected	ug/L	1	EPA 624	CW	11/6/2013
Chloroethane	Not detected	ug/L	1	EPA 624	CW	11/6/2013
2-Chloroethylvinyl ether	Not detected	ug/L	10	EPA 624	CW	11/6/2013
Chloroform	Not detected	ug/L	1	EPA 624	CW	11/6/2013
Chloromethane(Methyl Chloride)	Not detected	ug/L	1	EPA 624	CW	11/6/2013
cis-1,3-Dichloropropene	Not detected	ug/L	1	EPA 624	CW	11/6/2013
Dibromochloromethane	Not detected	ug/L	1	EPA 624	CW	11/6/2013
1,2-Dichlorobenzene	Not detected	ug/L	1	EPA 624	CW	11/6/2013
1,3-Dichlorobenzene	Not detected	ug/L	1	EPA 624	CW	11/6/2013
1,4-Dichlorobenzene	Not detected	ug/L	1	EPA 624	CW	11/6/2013
1,1-Dichloroethane	Not detected	ug/L	1	EPA 624	CW	11/6/2013
1,2-Dichloroethane	Not detected	ug/L	1	EPA 624	CW	11/6/2013
1,1-Dichloroethene	Not detected	ug/L	1	EPA 624	CW	11/6/2013
1,2-Dichloropropane	Not detected	ug/L	1	EPA 624	CW	11/6/2013
Ethyl benzene	Not detected	ug/L	1	EPA 624	CW	11/6/2013
Methylene chloride	Not detected	ug/L	5	EPA 624	CW	11/6/2013
1,1,2,2-Tetrachloroethane	Not detected	ug/L	1	EPA 624	CW	11/6/2013
Tetrachloroethene	Not detected	ug/L	1	EPA 624	CW	11/6/2013
Toluene	Not detected	ug/L	1	EPA 624	CW	11/6/2013
trans-1,2-Dichloroethene	Not detected	ug/L	1	EPA 624	CW	11/6/2013
trans-1,3-Dichloropropene	Not detected	ug/L	1	EPA 624	CW	11/6/2013
1,1,1-Trichloroethane	Not detected	ug/L	1	EPA 624	CW	11/6/2013
1,1,2-Trichloroethane	Not detected	ug/L	1	EPA 624	CW	11/6/2013
Trichloroethene	Not detected	ug/L	1	EPA 624	CW	11/6/2013



Brighton Analytical, L.L.C.
2105 Pless Drive
Brighton, Michigan 48116
Phone: (810) 229-7575 FAX: (810) 229-8650
e-mail: bai-brighton@sbcglobal.net

To: Ypsilanti Comm. Utilities Auth.
2777 State Rd.
Ypsilanti, MI 48198

Sample Date: 10/30/2013
Submit Date: 11/1/2013
Report Date: 11/8/2013

BA Report Number: 27057
BA Sample ID: BZ02771

Project Name: **Racer Trust CVO Site**
Project Number: **CA#94**
Sample ID: **Racer CVO Effluent**

Parameters	Results	Units	DL	Method Reference	Analyst	Analysis Date
Trichlorofluoromethane	Not detected	ug/L	1	EPA 624	CW	11/6/2013
Vinyl chloride	Not detected	ug/L	1	EPA 624	CW	11/6/2013

DL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

Released by:

Date:

[Signature]
11/8/13



Brighton Analytical, L.L.C.
2105 Pless Drive
Brighton, Michigan 48116
Phone: (810) 229-7575 FAX: (810) 229-8650
e-mail: bai-brighton@sbcglobal.net

To: Ypsilanti Comm. Utilities Auth.
2777 State Rd.
Ypsilanti, MI 48198

Sample Date: 10/30/2013
Submit Date: 11/1/2013
Report Date: 11/5/2013

BA Report Number: 27057
BA Sample ID: BZ02772

Project Name: **Racer Trust CVO Site**
Project Number: **CA#94**
Sample ID: **Racer CVO Effluent**

Parameters	Results	Units	DL	Method Reference	Analyst	Analysis Date
PCB Analysis						
ARO 1016	Not detected	ug/L	0.2	EPA 608	BY	11/4/2013
ARO 1221	Not detected	ug/L	0.2	EPA 608	BY	11/4/2013
ARO 1232	Not detected	ug/L	0.2	EPA 608	BY	11/4/2013
ARO 1242	Not detected	ug/L	0.2	EPA 608	BY	11/4/2013
ARO 1248	Not detected	ug/L	0.2	EPA 608	BY	11/4/2013
ARO 1254	Not detected	ug/L	0.2	EPA 608	BY	11/4/2013
ARO 1260	Not detected	ug/L	0.2	EPA 608	BY	11/4/2013
ARO 1262	Not detected	ug/L	0.2	EPA 608	BY	11/4/2013
ARO 1268	Not detected	ug/L	0.2	EPA 608	BY	11/4/2013
Total PCB	Not detected	ug/L	0.2	EPA 608	BY	11/4/2013
PCB liquid (extraction)	Extracted			3510C/3545	MB	11/4/2013

DL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

Released by: _____

Date: _____

[Signature]
11/8/13



Brighton Analytical, L.L.C.
2105 Pless Drive
Brighton, Michigan 48116
Phone: (810) 229-7575 FAX: (810) 229-8650
e-mail: bai-brighton@sbcglobal.net

To: Ypsilanti Comm. Utilities Auth.
2777 State Rd.
Ypsilanti, MI 48198

Sample Date: 10/30/2013
Submit Date: 11/1/2013
Report Date: 11/7/2013

BA Report Number: 27057
BA Sample ID: BZ02773

Project Name: **Racer Trust CVO Site**
Project Number: **CA#94**
Sample ID: **Racer CVO Effluent**

Parameters	Results	Units	DL	Method Reference	Analyst	Analysis Date
Semi-Volatile Analysis						
Acenaphthene	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Acenaphthylene	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Aniline	Not detected	ug/L	4	EPA 625	RG	11/5/2013
Anthracene	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Azobenzene	Not detected	ug/L	2	EPA 625	RG	11/5/2013
Benzo(a)anthracene	Not detected	ug/L	1	EPA 625	RG	11/5/2013
Benzo(a)pyrene	Not detected	ug/L	1	EPA 625	RG	11/5/2013
Benzo(b)fluoranthene	Not detected	ug/L	1	EPA 625	RG	11/5/2013
Benzo(ghi)perylene	Not detected	ug/L	1	EPA 625	RG	11/5/2013
Benzo(k)fluoranthene	Not detected	ug/L	1	EPA 625	RG	11/5/2013
Benzoic acid	Not detected	ug/L	50	EPA 625	RG	11/5/2013
Benzyl alcohol	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Bis(2-chloroethoxy)methane	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Bis(2-chloroethyl)ether	Not detected	ug/L	1	EPA 625	RG	11/5/2013
Bis(2-chloroisopropyl)ether	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Bis(2-ethylhexyl)phthalate	5	ug/L	5	EPA 625	RG	11/5/2013
4-Bromophenyl phenyl ether	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Butyl benzyl phthalate	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Carbazole	Not detected	ug/L	10	EPA 625	RG	11/5/2013
4-Chloro-3-methylphenol	Not detected	ug/L	5	EPA 625	RG	11/5/2013
4-Chloroaniline	Not detected	ug/L	10	EPA 625	RG	11/5/2013
2-Chloronaphthalene	Not detected	ug/L	5	EPA 625	RG	11/5/2013
2-Chlorophenol	Not detected	ug/L	5	EPA 625	RG	11/5/2013
4-Chlorophenol	Not detected	ug/L	5	EPA 625	RG	11/5/2013
4-Chlorophenyl phenyl ether	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Chrysene	Not detected	ug/L	1	EPA 625	RG	11/5/2013
Dibenzo(a,h)anthracene	Not detected	ug/L	2	EPA 625	RG	11/5/2013
Dibenzofuran	Not detected	ug/L	4	EPA 625	RG	11/5/2013
2,4-Dichlorophenol	Not detected	ug/L	5	EPA 625	RG	11/5/2013
2,6-Dichlorophenol	Not detected	ug/L	5	EPA 625	RG	11/5/2013



Brighton Analytical, L.L.C.
2105 Pless Drive
Brighton, Michigan 48116
Phone: (810) 229-7575 FAX: (810) 229-8650
e-mail: bai-brighton@sbcglobal.net

To: Ypsilanti Comm. Utilities Auth.
2777 State Rd.
Ypsilanti, MI 48198

Sample Date: 10/30/2013
Submit Date: 11/1/2013
Report Date: 11/7/2013

BA Report Number: 27057
BA Sample ID: BZ02773

Project Name: Racer Trust CVO Site
Project Number: CA#94
Sample ID: Racer CVO Effluent

Parameters	Results	Units	DL	Method Reference	Analyst	Analysis Date
Diethylphthalate	Not detected	ug/L	5	EPA 625	RG	11/5/2013
2,4-Dimethylphenol	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Dimethylphthalate	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Di-n-butylphthalate	Not detected	ug/L	5	EPA 625	RG	11/5/2013
4,6-Dinitro-2-methylphenol	Not detected	ug/L	20	EPA 625	RG	11/5/2013
2,4-Dinitrophenol	Not detected	ug/L	20	EPA 625	RG	11/5/2013
2,4-Dinitrotoluene	Not detected	ug/L	5	EPA 625	RG	11/5/2013
2,6-Dinitrotoluene	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Di-n-octylphthalate	Not detected	ug/L	5	EPA 625	RG	11/5/2013
1,2-Diphenylhydrazine	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Fluoranthene	Not detected	ug/L	1	EPA 625	RG	11/5/2013
Fluorene	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Hexachlorobenzene	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Hexachlorobutadiene	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Hexachlorocyclopentadiene	Not detected	ug/L	2	EPA 625	RG	11/5/2013
Hexachloroethane	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Indeno(1,2,3)pyrene	Not detected	ug/L	2	EPA 625	RG	11/5/2013
Isophorone	Not detected	ug/L	5	EPA 625	RG	11/5/2013
2-Methylnaphthalene	Not detected	ug/L	5	EPA 625	RG	11/5/2013
2-Methylphenol (o-Cresol)	Not detected	ug/L	5	EPA 625	RG	11/5/2013
3&4-Methylphenol(m&p-Cresol)	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Naphthalene	Not detected	ug/L	5	EPA 625	RG	11/5/2013
2-Nitroaniline	Not detected	ug/L	20	EPA 625	RG	11/5/2013
3-Nitroaniline	Not detected	ug/L	20	EPA 625	RG	11/5/2013
4-Nitroaniline	Not detected	ug/L	20	EPA 625	RG	11/5/2013
Nitrobenzene	Not detected	ug/L	2	EPA 625	RG	11/5/2013
2-Nitrophenol	Not detected	ug/L	5	EPA 625	RG	11/5/2013
4-Nitrophenol	Not detected	ug/L	20	EPA 625	RG	11/5/2013
N-Nitrosodimethylamine	Not detected	ug/L	5	EPA 625	RG	11/5/2013
N-Nitrosodi-n-propylamine	Not detected	ug/L	5	EPA 625	RG	11/5/2013
N-Nitrosodiphenylamine	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Pentachlorophenol	Not detected	ug/L	20	EPA 625	RG	11/5/2013



Brighton Analytical, L.L.C.
2105 Pless Drive
Brighton, Michigan 48116
Phone: (810) 229-7575 FAX: (810) 229-8650
e-mail: bai-brighton@sbcglobal.net

Sample Date: 10/30/2013
Submit Date: 11/1/2013
Report Date: 11/7/2013

To: Ypsilanti Comm. Utilities Auth.
2777 State Rd.
Ypsilanti, MI 48198

BA Report Number: 27057
BA Sample ID: BZ02773

Project Name: Racer Trust CVO Site
Project Number: CA#94
Sample ID: Racer CVO Effluent

Parameters	Results	Units	DL	Method Reference	Analyst	Analysis Date
Phenanthrene	Not detected	ug/L	2	EPA 625	RG	11/5/2013
Phenol	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Phenytain	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Pyrene	Not detected	ug/L	5	EPA 625	RG	11/5/2013
Pyridine	Not detected	ug/L	20	EPA 625	RG	11/5/2013
2,4,5-Trichlorophenol	Not detected	ug/L	5	EPA 625	RG	11/5/2013
2,4,6-Trichlorophenol	Not detected	ug/L	4	EPA 625	RG	11/5/2013
BNA liquid (extraction)	Extracted			3510C/3545	MB	11/5/2013

DL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

Released by:

Date:

Detron
11/8/13



2777 STATE ROAD
YPSILANTI, MI 48198-9112
TELEPHONE: (734) 484-4600

CHAIN-OF-CUSTODY (COC) RECORD

Original: IPP Supervisor / Cc: IPP File

270572411/1

Brighton Analytical, L.L.C. email: bai-brighton@abeglobal.net		BA PROJECT #: 27058 ABBREVIATIONS FOR MATRIX S = Solid L = Liquid DW = Drinking H ₂ O O = Oil P = Wipes A = Air (Tadair Bag) F = Filter T = Tube M = Misc.		PAGE <u> </u> OF <u> </u> COMPANY/MAILING ADDRESS: Ypsilanti Community Utilities Authority 2777 State Road Ypsilanti, MI 48198 ATTN: Luther Blackburn PHONE: 734-544-7123 FAX OR EMAIL: 734-544-7149 / lblackburn@cua.org Samples received within hold time? <u>yes</u> <u>no</u> Temperature of samples "C" <u>4</u> pHs verified in login? <u>yes</u> <u>no</u> Headspace/bubbles in VOA's? <u>yes</u> <u>no</u> <u>n/a</u> Sample containers and COC match? <u>yes</u> <u>no</u>	
PROJECT NAME: Racer Trust CVO Site PROJECT #: CA # 94 PO #: (PLEASE NOTE IF DIFFERENT BILLING ADDRESS)		Analysis Requested/Method Mercury ☒ Phenols ☒ VOCs (EPA 624) ☒ PCBs ☒ SVOCs (EPA 625) ☒			
Sample Collected By: AM REQUESTED TURNAROUND: (circle one) Rush: 1-3 business days (only with lab & specify date needed) 1 Day = 2.5X Cost 2 Day = 2X Cost 3 Day = 1.5X Cost Standard: 5 business days		Container/Quantity VOA S (PRES) - YES ☐ NO ☐ HDPE UNPRESERVED ☐ HDPE HNO ₃ ☐ HDPE H ₂ SO ₄ ☐ HDPE NaOH ☐ AMBER - PRESERVED ☐ GLASS - PRESERVATIVE ☐ AMBER - NOT PRESERVED ☐ METAL - YES ☐ NO ☐			
IF RUSH, approved by: _____ Sample Coll. Date Time 10/30/13 4:00p 10/30/13 9:36a 10/30/13 9:39a 2 10/30/13 4:00p 10/30/13 4:00p		Sample Description Racer CVO Effluent Racer CVO Effluent Racer CVO Effluent Racer CVO Effluent Racer CVO Effluent			
Brighton ID # 2) 70 3) 71 4) 72 5) 73 6) 7) 8) 9) 10)		Billing Address (if required): Drinking H ₂ O: FAX TO LCHD: yes no Chlorinated Water Supply? AMT: yes no MCL failure: yes no Client notified (date/time/initials):			

Please fill out the Chain of Custody completely and review. Incorrect or incomplete information will result in a "hold" on all analyses.

Trans. #	RELINQUISHED BY:	RECEIVED BY:	RELINQUISHED BY:	RECEIVED BY:	DATE:	TIME:	Trans. #	RELINQUISHED BY:	RECEIVED BY:	DATE:	TIME:
1					11-1-13	11:37a	3				
2					11-1-2013	2:30u	4				