



February 11, 2010

Mr. Richard Conforti, P.E.
Environmental Engineer
Waste and Hazardous Materials Division
Department of Natural Resources and Environment
PO Box 30241
Lansing, MI 48909-7741

*Subject: Monthly Status Report – January 2010
Coldwater Road Landfill
1245 East Coldwater Road, Flint, MI
MID 005 356 860 / Consent Order No. 64-05-92*

Dear Mr. Conforti:

In accordance with requirements of the above referenced Consent Order, we are providing you with this Monthly Status Report for the month of January 2010.

1. Work Completed This Reporting Period

- Dewatering of the leak detection vaults occurred on January 13, 2010.

2. Summaries of Findings

- None.

3. Summaries of Changes

- None.

4. Summaries of all Contact with Local Community

- None.

5. Summaries of all Problems

- Lost power due to broken switch at the transformer.

6. Actions Being Taken to Rectify Problems

- Consumers Energy fixed electrical problem on January 25, 2010.

7. Changes in Personnel

- David Favero replaces Ken Richards as the MLC project manager.

8. Projected Work

- Dewatering of the leak detection vaults is scheduled for February 10, 2010.
- Flushing of the force mains will be performed on February 1, 2010.
- Sampling and discharge of accumulated liquids will be conducted as needed.
- 2009 Annual groundwater monitoring, leak detection system and landfill inspection reports will be prepared for submittal to MDNRE on or before March 1, 2010.

9. Reports/Data

- Leak detection Vaults A, B, C, D, E and F were pumped on January 13, 2010. During January 2010, no water was removed from Vaults A, and D. However, 40 gallons were removed from Vault B, 33 gallons were removed from Vault C, 660 gallons were


Mr. Richard Conforti, P.E.

February 11, 2010

Page 2

removed from Vault E, and 21 gallons were removed from Vault F. Total volume of water removed from the vaults during the month of January was 834 gallons (including rinse water). According to the master flow meter, a total of 892 gallons were discharged to the accumulation tank; therefore, 58 gallons were pumped from the sumps during the month of January 2010.

The following graph presents the vault dewatering data in graphical format for the past year:



Please call me at 248-477-5701 if you have any questions.

Very truly yours,

O'BRIEN & GERE ENGINEERS, INC.

Clifford Yantz
Technical Associate

cc: Mr. David Favero – Motors Liquidation Company
Ms. Marianne Secrest – O'Brien & Gere