



April 13, 2015

Mr. Richard Conforti
Environmental Engineer
Office of Waste Management and Radiological Protection
Department of Environmental Quality
PO Box 30241
Lansing, MI 48909-7741

RE: *Quarterly Status Report –January 2015 – March 2015*
Coldwater Road Landfill
1245 East Coldwater Road, Flint, MI
MID 005 356 860
FILE: 15388/60794/Docs

Dear Mr. Conforti:

In accordance with requirements of the approved Post-Closure Care Plan, we are providing you with this Quarterly Status Report for the first quarter 2015.

1. Work Completed This Reporting Period

- » Dewatering of the leak detection vaults occurred on January 13, 2015, February 25, 2015 (Vault E), and March 17, 2015.
- » The annual groundwater monitoring, leak detection system (LDS) and landfill inspection reports were prepared and submitted to the MDEQ on February 11, 2015.
- » Sampling of accumulated liquids was conducted on February 18, 2015.
- » Discharge of liquids from the accumulation tank occurred on March 9, 2015.
- » The first quarter 2015 site inspection occurred on March 18, 2015.

2. Summaries of Findings

- » None.

3. Summaries of Changes

- » None.

4. Summaries of all Contact with Local Community

- » None.

5. Summaries of all Problems

- » None.

6. Actions Being Taken to Rectify Problems

- » None.

7. Changes in Personnel

- » None.

8. Projected Work

- » Dewatering of the leak detection vaults is scheduled for April 15, 2015, May 14, 2015, and June 17, 2015.
- » Sampling and discharge of accumulated liquids will be conducted as needed.
- » The second quarter 2015 site inspection will be conducted in June 2015.
- » Semi-annual groundwater and LDS monitoring will be conducted during the second or third weeks of June 2015, weather dependant.


9. Reports/Data

- » Leak detection Vaults A, B, C, D, E and F were pumped on January 13, 2015, February 25, 2015 (Vault E), and March 17, 2015.
- » The following table presents the vault dewatering and monthly leachate sump data for the first quarter:

DATE 2015	GALLONS LEAK DET A	GALLONS LEAK DET B	GALLONS LEAK DET C	GALLONS LEAK DET D	GALLONS LEAK DET E	GALLONS LEAK DET F	TOTAL LEAK GALLONS	MONTHLY SUMP VOLUMES GALLONS
13-Jan-15	135	223	27	44	860	40	1,329	558
25-feb-15	--	--	--	--	825	--	825	1,157
17-Mar-15	70	130	28	6	414	23	671	42
TOTAL	205	353	55	50	2,099	63	2,825	1,757

Total volume of water removed from the vaults during the first quarter was 2,825 gallons. According to the master flow meter and discharge records, a total of 1,757 gallons were pumped from the sumps during the first quarter.

The following graph presents the vault dewatering data in graphical format for the past year:



10. Active Task 2015 Budget Status

- » Task 1 – Continue Ongoing OMM: 25% complete, 26% of 2015 budget.
- » Task 4 – Fe & Mn Delineation: 63% complete, 63% of 2015 budget.
- » Task 6 – Agency Coord./Negotiation & Reporting: 25% complete, 15% of 2015 budget.
- » Task 7 – Project Management & Coordination: 25% complete, 30% of 2015 budget.

Please call me at 248-477-5701 x16 if you have any questions.

Very truly yours,

O'BRIEN & GERE ENGINEERS, INC.



Clifford Yantz
Scientist-3

cc: Mr. Grant Trigger – RACER Trust
Mr. David Favero – RACER Trust
Mr. Kevin Schneider – O'Brien & Gere