

## **Landale, Beth**

---

**From:** Landale, Beth  
**Sent:** Tuesday, May 15, 2012 5:12 PM  
**To:** LBlackburn@ycua.org  
**Cc:** Project Email Hold; Bains, Amandeep; Grant Trigger; Dave Favero; Kuhl, Nathan  
**Subject:** Industrial User Permit # RA 6-12 ~MSC-017303~

Hi Luther,

We received data from our last treatment cycle that was completed on May 3, 2012. The results of the effluent were 1.1 mg/L for vinyl chloride. This exceeds our permit limit of 0.2 mg/L. We are in the process of assessing the cause and will follow up with the required written report within 30 days as required by our permit.

If you have any questions, please feel free to contact me.

Thank you,

Beth

---

**Beth Landale P.Eng., P.E.**  
**Conestoga-Rovers & Associates (CRA)**  
14496 Sheldon Road, Suite 200  
Plymouth, Michigan 48170

**Phone: 734-453-5123**

**Direct Dial: 734-357-5528**

**Mobile: 734-545-5423**

**Fax: 734-453-5201**

**Email: [blandale@CRAworld.com](mailto:blandale@CRAworld.com)**

**[www.CRAworld.com](http://www.CRAworld.com)**

**Perform every task the safe way, the right way, every time!**